

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/11/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155747		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 12/07/2012	
NAME OF PROVIDER OR SUPPLIER WOODCREST NURSING CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 1300 MERCER AVE DECATUR, IN 46733			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>INITIAL COMMENTS</p> <p>A Post Survey Revisit (PSR) to the PSR conducted on 11/13/12 to the Life Safety Code Recertification, State Licensure and Quality Assurance Walk-thru Surveys conducted on 09/19/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).</p> <p>Survey Date: 12/07/12</p> <p>Facility Number: 000556 Provider Number: 155747 AIM Number: 100290130</p> <p>Surveyor: Amy Kelley, Life Safety Code Specialist</p> <p>At this PSR survey, Woodcrest Nursing Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The original section of the building consisting of A Wing, C Wing, the Extended Care Wing and the main dining room was surveyed with Chapter 19, Existing Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, areas open to the corridors and hard wired smoke detectors in the resident rooms. The facility has a capacity of 143 and had a census of 124 at the time of this survey.</p>			{K 000}			

LABORATORY DIRECTOR'S OR PROVIDER/SUPPLIER REPRESENTATIVE'S SIGNATURE

TITLE

(X6) DATE

Any deficiency statement ending with an asterisk (*) denotes a deficiency which the institution may be excused from correcting providing it is determined that other safeguards provide sufficient protection to the patients. (See instructions.) Except for nursing homes, the findings stated above are disclosable 90 days following the date of survey whether or not a plan of correction is provided. For nursing homes, the above findings and plans of correction are disclosable 14 days following the date these documents are made available to the facility. If deficiencies are cited, an approved plan of correction is requisite to continued program participation.

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/11/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155747		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 12/07/2012	
NAME OF PROVIDER OR SUPPLIER WOODCREST NURSING CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 1300 MERCER AVE DECATUR, IN 46733			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	Continued From page 1			{K 000}			
	The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.						
	All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered.						
	Quality Review by Robert Booher, Life Safety Code Specialist-Medical Surveyor on 12/10/12.						
{K 000}	INITIAL COMMENTS			{K 000}			
	A Post Survey Revisit (PSR) to the PSR conducted on 11/13/12 to the Life Safety Code Recertification, State Licensure and Quality Assurance Walk-thru Surveys conducted on 09/19/12 was conducted by the Indiana State Department of Health in accordance with 42 CFR 483.70(a).						
	Survey Date: 12/07/12						
	Facility Number: 000556						
	Provider Number: 155747						
	AIM Number: 100290130						
	Surveyor: Amy Kelley, Life Safety Code Specialist						
	At this PSR survey, Woodcrest Nursing Center was found in compliance with Requirements for Participation in Medicare/Medicaid, 42 CFR Subpart 483.70(a), Life Safety from Fire and the 2000 edition of the National Fire Protection Association (NFPA) 101, Life Safety Code (LSC) and 410 IAC 16.2. The Rehabilitation Administration addition including a rehabilitation						

DEPARTMENT OF HEALTH AND HUMAN SERVICES
CENTERS FOR MEDICARE & MEDICAID SERVICES

PRINTED: 12/11/2012
FORM APPROVED
OMB NO. 0938-0391

STATEMENT OF DEFICIENCIES AND PLAN OF CORRECTION		(X1) PROVIDER/SUPPLIER/CLIA IDENTIFICATION NUMBER: 155747		(X2) MULTIPLE CONSTRUCTION A. BUILDING 01 , 02 B. WING _____		(X3) DATE SURVEY COMPLETED R 12/07/2012	
NAME OF PROVIDER OR SUPPLIER WOODCREST NURSING CENTER				STREET ADDRESS, CITY, STATE, ZIP CODE 1300 MERCER AVE DECATUR, IN 46733			
(X4) ID PREFIX TAG	SUMMARY STATEMENT OF DEFICIENCIES (EACH DEFICIENCY MUST BE PRECEDED BY FULL REGULATORY OR LSC IDENTIFYING INFORMATION)			ID PREFIX TAG	PROVIDER'S PLAN OF CORRECTION (EACH CORRECTIVE ACTION SHOULD BE CROSS-REFERENCED TO THE APPROPRIATE DEFICIENCY)		(X5) COMPLETION DATE
{K 000}	<p>Continued From page 2</p> <p>pool, apartment, nurses' station and offices was surveyed with Chapter 18, New Health Care Occupancies.</p> <p>This one story facility was determined to be of Type V (111) construction and was fully sprinklered. The facility has a fire alarm system with smoke detection in corridors, areas open to the corridors and hard wired smoke detectors in the resident rooms. The facility has a capacity of 143 and had a census of 124 at the time of this survey.</p> <p>The facility was found in compliance with state law in regard to sprinkler coverage and smoke detector coverage.</p> <p>All areas where the residents have customary access were sprinklered. All areas providing facility services were sprinklered.</p>			{K 000}			